

CERTIFICATE

Permission to use the test mark

***VOLUNTARY PRODUCT TEST
BASED ON DIN 1946-4:2018 AND VDI 6022-1:2018
– Tested Hygiene Characteristics –***

TÜV NORD Systems GmbH & Co. KG, Hamburg (Germany),

hereby confirms that the Air Handling Unit Range

“D-AHU” in Hygienic Version

conforms to the requirements set by DIN 1946-4 and VDI 6022-1.

**DAIKIN Applied Europe S.p.A,
Calepio di Settala (MI) (Italy),**

is therefore granted the right to use the test mark shown below
in connection with the above-mentioned product.

TÜV NORD Systems GmbH & Co. KG
Test Laboratory for Ventilation, Air Conditioning, Refrigeration



Dipl.-Ing. Monika Steimle

Essen, 03 May 2024

The certification is based upon a type examination of an Air Handling Unit and not of a complete system installed in a building.
The validity of the certificate is 15 months.
All regulations concerning test mark use are laid down in the corresponding agreement.

